


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 995 | m - 20 | 23

Dated: 23.04.2026

It is certified that an inspection team headed by Er. Rameshwar Dayal (Executive Engineer) (Name of Officers with designation) from Uttar Pradesh Jal Nigam (Rural), Mau PHED Inspected the **Unity Academy Rajendra Nagar, Mau** (Name & Address of the school) on **22.04.2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. TC/MAU/26/28 dated **23.04.2026** of District Level water analysis Laboratory, U.P. Jal nigam (Rural), Mau (PHED Lab) certified that the **Unity Academy Rajendra Nagar, Mau** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **1 year**.

Signature with Seal: 
Name : Rameshwar Dayal
Designation : Executive Engineer
Name & Address of the Office/Department:

**Executive Engineer
Division Office
U.P. Jal Nigam (Rural)
Mau**

To,

Unity Academy Rajendra Nagar, Mau
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

Water Analysis Report



District Level Water Analysis Laboratory

UP Jal Nigam (Rural) - Mau

Office of the Executive Engineer, Division office

UP Jal Nigam (Rural), Mau- 275101

Report No.: TC/MAU/26/28

Date: 23.04.2026

Page No.: 1

Customer Details

Office Name and Address

Unity Academy Rajendra Nagar, Mau

Basic Details of Sample

District		Mau	Block	Dohari ghat		
Habitation		School campus	Location	Rajendra Nagar		
Water Source		Submersible	Sample Code	MAU/26/04/03		
Quantity of Sample		1000 ml (Normal)	Sampling date	22.04.2026		
Sample Received Date		22.04.2026	S. collected by	Abhishek Yadav		
Sampling Method Used		As per SOP	Sample Depositor	Abhishek Yadav		
Analysis Start Date		22.04.2026	Analysis Completion date	23.04.2026		
Temperature(°C)		26°C	Humidity (%)	50%		
S. No.	Analysed Parameters	Unit	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1.	Colour	(Hazen)	<5	5	15	APHA 24th Edition-2120
2.	pH	-	7.62	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022
3.	Turbidity	NTU	1.20	1	5	IS 3025 (Part 10):2023
4.	Total Dissolved Solids	mg/l	460	500	2000	IS 3025 (Part 16): 2024
5.	Total Hardness (as CaCO3)	mg/l	192	200	600	IS 3025 (Part 21): 2023
6.	Calcium (as Ca)	mg/l	36.0	75	200	IS 3025 (Part 40): 2019
7.	Magnesium (as Mg)	mg/l	37.9	30	100	IS 3025 (Part 46): 2024
8.	Chloride (as Cl)	mg/l	31.9	250	1000	IS 3025 (Part 32): 2019
9.	Total Alkalinity (as CaCO3)	mg/l	198	200	600	IS 3025 (Part 23): 2023
10.	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
11.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
12.	Sulphate (as SO4)	mg/l	20.3	200	400	APHA 24th Edition-4500-SO4 Method E (Turbidimetric Method): 2023
13.	Nitrate (as NO3)	mg/l	2.28	45	No relaxation	APHA 24th Edition-4500-NO3 Method B (UV Screening Method): 2023
14.	Iron (as Fe)	mg/l	0.25	1.0	No relaxation	3500-Fe Method B APHA 24th Ed (Phenanthroline method)
15.	Fluoride (as F)	mg/l	BDL	1.0	1.5	APHA 24th Edition-4500-F Method C (Ion-Selective Electrode Method) : 2023

Note:

1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in **bold**. (BDL=Below detection limit)
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab.

(Report Reviewed by)



END OF THE ANALYSIS REPORT